



Elektrinis kanalinis šildytuvas

Electric duct heater

Elektro-Heizregister für Lüftungssysteme

Электрические каналные нагреватели



Elektriniai kanaliniai šildytuvai skirti švaraus oro pašildymui ventiliacijos sistemose.

Korpusai pagaminti iš skardos, padengtos AlZn, kurios paviršius atsparus aukštai temperatūrai. Kaitinimo elementų vamzdelis pagamintas iš nerūdijančio plieno AISI 304.

Šildytuvuose yra sumontuotos dvi termoapsaugos, elektrinio pajungimo gnybtai. Korpusai gaminami su PG jungtimis, flanšais arba skirti montuoti tiesiai į vėdinimo įrenginius.

Šildytuvai gali būti montuojami horizontaliai ir vertikaliai. Maksimali pašildyto oro temperatūra 50°C.



Elektrische Heizgeräte werden entworfen, um saubere Luft in Lüftungssystemen zu heizen. Die Verschalung wird von beschichtetem Stahl von aluzinc gemacht, der hohe Temperaturbeweis ist. Heizelement-Tube wird vom Edelstahl AISI 304 gemacht. In Heizungen werden 2 Schutzthermostate, Schraube-Terminals für die leichte Verbindung installiert. Das Gehäuse kann mit PG-Anschluss, Flanschen oder für die Montierung gerade in die Lüftungsgeräte geeignet sein.

Heizungen können vertikal oder horizontal installiert werden.

Maximale Produktionslufttemperatur 50°C.



Electrical duct heater

Electric heaters are designed to heat clean air in ventilation systems.

Casing is made from aluzinc coated steel which is high temperature proof. Heating elements tube is made from stainless steel AISI 304.

In heaters are installed 2 protection thermostats, screw terminals for easy connection. Casing can be with PG connection, flanges or intended to install directly to AHU.

Heaters can be installed vertically or horizontally.

Maximum output air temperature 50°C.



Электрические каналные нагреватели предназначены для подогрева чистого воздуха в вентиляционных системах. Корпус изготовлен из алюмоцинкованной стали, поверхность которой устойчива к высоким температурам. Трубка тена изготовлена из нержавеющей стали AISI 304. В нагревателе установлены 2 термозащиты, клеммы электрического подключения, корпус может быть изготовлен с PG соединением, с фланшами или для монтирования в вент. агрегат.

Нагреватели могут быть установлены горизонтально и вертикально.

Максимальная температура подогреваемого воздуха 50°C.

Accessories



TJK
p. 150



EKR 15,
EKR 15P
p. 140-141

Power steps

Total rated power [kW]	Steps
9	9
12	12
15	15
18	9 + 9
21	9 + 12
24	9 + 15
27	12 + 15
30	15 + 15
33	15 + 18
36	9 + 12 + 15
39	9 + 15 + 15
42	12 + 15 + 15
45	12 + 15 + 18
51	9 + 12 + 12 + 18
54	9 + 12 + 15 + 18
60	12 + 15 + 15 + 18
66	15 + 15 + 18 + 18

Power requirements

Heating power range of manufactured EKS heaters varies from 0,3 kW to 300 kW.

Calculation of required heater power:

$$P = Q * 0,36 * (t_2 - t_1)$$

I.e.: **P** - heating power [W],
Q - airflow [m³/h],
t₁ - temperature of incoming air [°C],
t₂ - required air temperature [°C].

Overheat protection

Minimum air velocity is 1,5 m/s.

All EKS duct heaters has two-stage overheat protection: the first stage switches on when the temperature reaches 50°C (resets automatically), the second stage switches on when the temperature reaches 100°C (is reset manually with pushbutton on the casing).

EKS has no internal temperature controller. External heat-controllers EKR are used in this case.


Pressure drop

Pressure drop across a duct heater depends on air velocity and the number of rows of heating elements (with reference to diagram).

Calculation of heating element rows number:

$$X = P / (A * 15)$$

I.e.: **X** - approx. number of heating element rows
P - total rated power [kW],
A - cross sectional area [m²].



Surface temperature of heating element

Surface temperature of heating elements depend on air velocity and surface heating power rating of the element (approx. 3 W/cm²). The diagram illustrates the surface temperature of the element as a function of air velocity at an air output temperature of approx. 20°C from the heater.

